

State of Idaho
DEPARTMENT OF INSURANCE

JAMES E. RISCH
Governor

DIVISION OF
STATE FIRE MARSHAL
700 West State Street, 3rd Floor
P.O. Box 83720
Boise, Idaho 83720-0043
Phone (208)334-4370
Fax (208)334-4375

SHAD PRIEST
Acting Director

MARK A. LARSON
State Fire Marshal

RECORD OF INSPECTION
Based on 2003 Edition IFC

DATE:

Name of Fire Dept. Conducting Inspection:

Name of State Certified Fire Inspector:

Business Name:

Business Address:

City/State/Zip :

Phone:

1. Type of Construction :

2. Occupancy Classification :

3. Height:

4. Length:

5. Width:

6. Sq. Footage:

7. Occupant Load:

8. No. of Stories:

9. Attic: Yes No

10. Basement: Yes No

11. No. Residential Units:

12. Key Box: Yes No

13. Fire Alarm System: Yes No Type of System : Manual Automatic Both

14. Fire Sprinkler System: Yes No Type of Sprinkler system :

15. Status of Construction:

16. Status of Repair:

Answer the following Yes, No or Not Required.

ADDRESS

17. Is address posted ? (IFC sec. 505.1) _____.

Comments:

OCCUPANCY

18. Is occupant load posted ? (IFC sec. 1004.3) _____.

Comments:

EXITS

19. Proper number of exits (IFC sec. 1018)_____.

20. Proper exit door swing (IFC sec. 1008.1.2)_____.

21. Proper door locks installed (IFC sec. 1008.1.8.3 Thru 1008.1.9)_____.

22. Is panic hardware required ? (IFC sec. 1008.1.9)_____.

23. Are exits maintained unobstructed ? (IFC sec. 1027.3)_____.

24. Are proper exit signs installed ? (IFC sec. 1011.1)_____.

25. Are exit signs properly illuminated ? (IFC sec. 1011.2)_____.

26. Exit sign tested okay : _____.

Comments:

EMERGENCY LIGHTING

27. Is emergency lighting required ? (IFC sec. 1006.1)_____.

28. Is emergency lighting operational ? _____.

Comments:

STAIRWAYS

29. Are stairways maintained in compliance ? (IFC sec. 1009) _____.

30. Are handrails present ? (IFC sec. 1009.11) _____.

31. Is there storage under stairways ? (IFC sec. 1019.1.5) _____.

Comments:

HEATING EQUIPMENT

Type of heating system:

32. Is proper clearance Provided ? (IFC sec. 603.5)_____.

33. Is equipment properly vented ? _____.

34. Is equipment properly enclosed ?_____.

Comments:

ELECTRICAL

35. Is electrical wiring in good repair ? (IFC sec. 605.1)_____.

36. Are extension cords being used properly ? (IFC sec. 605.5) _____.

37. Is there storage around electrical panels and switchboards ? (IFC sec. 605.3)_____.

38. Is access provided to electrical panels and switchboards ? (IFC sec. 605.3)_____.

39. Are electrical panel and switchboard disconnects identified/labeled ? (IFC sec. 605.3.1)_____.

Comments:

COMMERCIAL KITCHENS

40. Is proper hood system provided ? (IFC 610.2)_____.

41. Are hoods, fans, filters and ducts maintained in clean condition ? (IFC sec. 904.11.6.3)_____

42. Has hood extinguishing system been serviced and maintained ? (IFC sec.904.11.6.4)_____
43. Is extinguishing system manual operation device accessible ? (IFC sec. 904.11.1) _____
44. Is a Class K rated Fire Extinguisher provided in the kitchen ? (IFC sec. 904.11.5) _____

Comments:

SERVICE STATIONS

45. Are no smoking and stop engine signs posted ? (IFC sec. 2205.6) _____
46. Are fueling systems maintained in proper operating condition ? (IFC sec. 2206.7) _____.
47. Are emergency shutdown devices located within 100 ft. of dispensers ? (IFC sec. 2203.2)_____
48. Is fuel burning heating equipment located at least 18 inches above the floor? (IFC sec. 2201.6) _____

Comments:

HOUSEKEEPING

49. Is trash and rubbish routinely removed from the building ? (IFC sec. 304.1) ____.
50. Are oily rags stored correctly ? (IFC sec. 304.3.1) _____.
51. Is the area outside the building clean and free of combustible materials ? (IFC sec. 304.1.1 and 304.1.2) ____.
52. Is trash receptacle located a proper distance from the building ? (IFC sec. 304.3.3) _____.

Comments:

FLAMMABLE LIQUID STORAGE

53. Is there storage of class I liquids ? (IFC sec. 3404.3.4) _____.
Amount in gallons _____
54. Is there storage of class II and class III liquids? (IFC sec. 3404.3.4) _____.
Amount in gallons _____
55. Are flammable liquids stored in storage cabinets ? (IFC sec. 3404.3.2) _____.

56. Are flammable liquids stored in special storage rooms ?(IFC sec. 3404.3.7)_____.

Comments:

STORAGE

57. Is storage neat and orderly ? (IFC sec. 315.2) _____.

58. Is storage 24 inches below ceiling and 18 inches below sprinkler heads? (IFC sec. 315.2.1)_____.

59. Is storage found in exits or exit enclosures ? (IFC sec. 315.2.2) _____.

60. Is there storage in equipment rooms ? (IFC sec. 315.2.3) _____.

61. Is there storage in attic, under-floor and concealed areas ? (IFC sec. 315.2.4)_____.

Comments:

COMPRESSED GAS STORAGE

62. Are gas cylinders properly secured ? (IFC sec. 3003.3.3) _____.

63. Are tanks stored in an upright position? (IFC sec. 3004.1) _____.

64. Are tanks protected from physical damage ? (IFC sec. 3003.3.2) _____.

65. Are tanks separated from combustible waste and vegetation ? (IFC sec. 3003.5.2) _____.

Comments:

NATURAL GAS

66. Is the meter and outside piping protected from physical damage? (IFC sec. 2703.9.3) _____.

Comments:

FIRE-RESISTIVE CONSTRUCTION

67. Is required fire-resistive construction in tacked and in good repair? (IFC sec. 703.1) _____.

68. Are required fire assemblies unobstructed and in good operating order ? (IFC 703.2)_____.

69. Are interior ceilings and walls in good repair ? (IFC sec. 703.1) _____.

Comments:

PORTABLE FIRE EXTINGUISHERS

70. Are fire extinguishers of the proper type and size provided ? (IFC sec. 906.3)

_____.

71. Are fire extinguishers mounted properly ? (IFC sec. 906.9) _____.

72. Are fire extinguishers being serviced and maintained annually ? (IFC sec. 901.6.1 and NFPA 10) _____.

Comments:

FIRE SPRINKLER SYSTEMS

73. Is fire sprinkler system maintained properly? (IFC sec. 901.6) _____

74. Is proper clearance being maintained below sprinkler heads ? (IFC sec. 903.3.3 & 315.2.1) _____.

75. Are standpipes required ? (IFC sec.905.3) _____.

76. Are standpipes properly maintained ? (IFC sec. 901.6) _____.

Comments:

FIRE ALARM SYSTEMS

77. Is a fire alarm system required? (IFC sec. 907.2) _____.

78. Is the alarm system properly maintained /(IFC sec. 907.20)_____

79. Are smoke detectors required? (IFC sec. 907.2) _____

Comments:

INSPECTED BY:_____ DATE:_____

I HEREBY ACKNOWLEDGE INSPECTION OF THE PREMISES.

OWNER/REPRESENTATIVE:_____DATE:_____

FOLLOW-UP INSPECTION DATE:_____